

C E R T I F I C A T E
of Conformity



Registration No.: AK 50490881 0001

Report No.: 50420945 001

Holder: **Ginlong technologies Co., Ltd.**
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification: Type Designation : Solis-80K-5G Solis-100K-5G
Solis-110K-5G
Serial Number : Engineering Samples
Firmware version : 1F
Remark(s) : Refer to report 50420945 001
for details.

Tested acc. to: RD 1699:2011
UNE 206006 IN:2011
UNE 206007-1 IN:2013

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 28.12.2020


Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



| Modelo Model | Solis-80K-5G | Solis-100K-5G | Solis-110K-5G |
|---|------------------------|------------------------|------------------------|
| Potencia nominal CA Nominal AC Power | 80000 W | 100000 W | 110000 W |
| Tensión nominal CA Nominal AC voltage | 230 V | 230 V | 230 V |
| Corriente máxima CA Maximal AC current | 133.7 A | 167.1 A | 183.8 A |
| Frecuencia nominal Nominal frequency | 50 Hz | 50 Hz | 50 Hz |
| Rango de tensión MPPT MPPT voltage range | 180-1000V | 180-1000V | 180-1000V |
| Tensión CC máxima Max. DC voltage | 1100 V | 1100 V | 1100 V |
| Corriente DC máxima Max. DC current | 9*26 A | 10*26 A | 10*26 A |
| Elemento de control Control device | Controller in Inverter | Controller in Inverter | Controller in Inverter |
| Tipo de dispositivo de control Type of control device | Integrated | Integrated | Integrated |

Ginlong technologies Co., Ltd.
Zhang Kun

Date : 28.12.2020
Our ref. : CSC 01
Your ref.: Kun Zhang

No.57 Jintong Road, Binhai,
(seafont), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50490881 0001
Report No. : 50420945 001

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Weichun Li

CC: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询